



FINISH: CLEAR ANODIZED
QTY.: TO BE DETERMINED

NOTES:

- 1) POWER POLES SHALL BE TWO COMPARTMENT AS INDICATED ABOVE.
- 2) POWER POLES SHALL BE FACTORY PREWIRED. ALL WIRING SHALL BE #10AWG THHN TYPE.
- 3) ALL CIRCUIT BREAKERS SHALL BE MANUFACTURED BY SQUARE D AND SHALL BE SERIES RATED WITH UPSTREAM DISCONNECT BREAKERS TO MAINTAIN A SHORT CIRCUIT RATING OF 10,000 AIC.

BILL OF MATERIAL

ITEM #	QTY.	DESCRIPTION
1	4	5-20R
2	2	1 POLE C/B, QOU120, 20A
3	1	HBL2320, L6-20R, T/L RECEPTACLE
4	1	2 POLE C/B, QOU220, 20A
5	1	8' POWER CORD (#10,5 WIRE FEED) W/STRAIN RELIEF, PLUG (HBL2811S), & KELLEM GRIP
6	2	PLASTIC GROMMET, FOR 2" DIA.

FOR:

FOR REFERENCE ONLY

S.O. NUM.:

STD. PWRP03002.xls ACAD STD.: PWRP03002



POST GLOVER LIFELINK
4750 OLYMPIC BLVD. BLDG. B
ERLANGER, KY U.S.A. 41018 (859) 283-5900
COPYRIGHT © 2004

THIS DOCUMENT AND THE INFORMATION IT CONTAINS ARE THE PROPERTY OF POST GLOVER LIFELINK. IT IS DISCLOSED FOR THE PURPOSE FOR WHICH IT IS FURNISHED AND SHALL NOT BE DUPLICATED OR DISTRIBUTED.

TITLE/DESCRIPTION:
SERIES 155 POWER POLE
TYPE: DETAIL OF TYPE 2

DFTR: JJM DATE: 01/29/03 DWG. NO.: PWRP03002 REV.: 00